



ALLEN COUNTY, INDIANA BUILDING DEPARTMENT

200 E. Berry Street/Suite 180 FORT WAYNE, INDIANA 46802-1299 PHONE: (260) 449-7131
George M. Smith, Allen County Indiana Building Commissioner

ATTENTION HEATING CONTRACTORS PULLING KITCHEN HOOD PERMITS

When pulling a heating permit to install kitchen hood systems, the following guidelines will apply when scheduling a "**Grease Duct Light Test**" inspection:

- 1) A minimum 100w or 100w equivalent light bulb without a solid guard needs to be installed.
- 2) All ducts and fitting seams welded in contractor shop shall be light tested by the contractor prior to being delivered to the job site.
- 3) All welds done on job site shall have a light test and any holes found will need welded prior to inspector arriving at the job site.
- 4) When inspector arrives at job site, the light, extension cords and ladders shall be ready for inspection.
- 5) Grease duct inspections shall be performed prior to overhead installation. Inspections requested post installation is subject to penalty due to amount of time required compared to pre-installation inspection.

Any procedure that fails may be subject to a penalty and possibly subject to a re-scheduling of inspection.